



PDHonline Course E139 (6 PDH)

**Automatic Control Systems - Part
II: Laplace Transform and Time-
Domain Analysis**

Instructor: Shih-Min Hsu, Ph.D., P.E.

2012

PDH Online | PDH Center

5272 Meadow Estates Drive
Fairfax, VA 22030-6658
Phone & Fax: 703-988-0088

www.PDHonline.org
www.PDHcenter.com

An Approved Continuing Education Provider

Automatic Control Systems

Part II:

Laplace Transform and Time-Domain Analysis

By Shih-Min Hsu, Ph.D., P.E.

IV. Laplace Transform:

The Laplace transform is one of the mathematical tools used for the solution of ordinary linear differential equations. The Laplace transform method has the following two attractive features:

1. The homogeneous equation and the particular integral are solved in one operation.
2. The Laplace transform converts the differential equation into an algebraic equation in s . It is possible to manipulate the algebraic equation by simple algebraic rules to obtain the solution in the s -domain. The final solution is obtained by taking the inverse Laplace transform.

Definition of the Laplace Transform:

Given the function $f(t)$ that satisfies the condition:

$$\int_0^{\infty} |f(t)e^{-\sigma t}| dt < \infty, \quad (4-1)$$

for some finite real σ , the Laplace transform of $f(t)$ is defined as

$$F(s) = \int_0^{\infty} f(t)e^{-st} dt, \quad (4-2)$$

or

$$F(s) = \mathcal{L}[f(t)]. \quad (4-3)$$

The variable s is referred to as the Laplace operator, which is a complex variable, $s = \sigma + j\omega$, where σ is the real part and ω is the imaginary part, as shown in Figure 4-1.




Fig. 4-1. Graphical presentation of Laplace operator (s-Plane).

Example 4-1: Let $f(t)$ be a unit step function that is defined to have a constant value of unity for $t \geq 0$ and a zero for $t < 0$, namely, $f(t) = u_s(t)$. What is its Laplace transform $F(s)$?

Solution:

$$F(s) = \int_0^{\infty} f(t)e^{-st} dt = \int_0^{\infty} u_s(t)e^{-st} dt = -\frac{1}{s}e^{-st} \Big|_0^{\infty} = -\frac{1}{s}[0 - 1] = \frac{1}{s} \quad \blacklozenge$$

Example 4-2: Let $f(t)$ is an exponential function, $f(t) = e^{-at}$ $t \geq 0$, where a is a constant. What is its Laplace transform $F(s)$?

Solution:

$$F(s) = \int_0^{\infty} f(t)e^{-st} dt = \int_0^{\infty} e^{-at} e^{-st} dt = \int_0^{\infty} e^{-(s+a)t} dt = -\frac{1}{(s+a)}e^{-(s+a)t} \Big|_0^{\infty} = \frac{1}{s+a} \quad \blacklozenge$$

Important Theorems of the Laplace Transform:

1. Multiplication by a constant-

$$\mathcal{L}[kf(t)] = kF(s) \tag{4-4}$$

2. Sum and difference-

$$\mathcal{L}[f_1(t) \pm f_2(t)] = F_1(s) \pm F_2(s) \tag{4-5}$$

3. Differentiation-

$$\mathcal{L}\left[\frac{df(t)}{dt}\right] = sF(s) - \lim_{t \rightarrow \infty} f(t) = sF(s) - f(0) \tag{4-6}$$

$$\mathcal{L}\left[\frac{d^n f(t)}{dt^n}\right] = s^n F(s) - s^{n-1}f(0) - s^{n-2}f'(0) - \dots - f^{(n-1)}(0) \tag{4-7}$$

where $f^{(k)}(0) = \left. \frac{d^k f(t)}{dt^k} \right|_{t=0}$.

4. Integration-

$$\mathcal{L}\left[\int_0^t f(\tau) d\tau\right] = \frac{F(s)}{s} \tag{4-8}$$

$$\mathcal{L}\left[\int_0^{t_1} \int_0^{t_2} \dots \int_0^{t_{n-1}} \int_0^{t_n} f(\tau) d\tau dt_1 dt_2 \dots dt_{n-2} dt_{n-1}\right] = \frac{F(s)}{s^n} \tag{4-9}$$

5. Shift in time-

$$\mathcal{L}[f(t - T)u_s(t - T)] = e^{-Ts}F(s) \tag{4-10}$$

6. Initial-value theorem-

$$\lim_{t \rightarrow 0} f(t) = \lim_{s \rightarrow \infty} sF(s) \tag{4-11}$$

7. Final-value theorem-

$$\lim_{t \rightarrow \infty} f(t) = \lim_{s \rightarrow 0} sF(s) \tag{4-12}$$

8. Complex shifting-

$$\mathcal{L}[e^{\mp at} f(t)] = F(s \pm a) \tag{4-13}$$

9. Real convolution (Complex multiplication)-

$$F_1(s)F_2(s) = \mathcal{L}\left[\int_0^t f_1(\tau)f_2(t - \tau) d\tau\right] = \mathcal{L}\left[\int_0^t f_2(\tau)f_1(t - \tau) d\tau\right] = \mathcal{L}[f_1(t) * f_2(t)] \tag{4-14}$$

where * denotes complex convolution.

Inverse Laplace Transformation:

The operation of obtaining $f(t)$ from the Laplace transform $F(s)$ is called the inverse Laplace transformation. The inverse Laplace transform of $F(s)$ is expressed as follows

$$f(t) = \mathcal{L}^{-1}F(s) = \frac{1}{2\pi j} \int_{c-j\infty}^{c+j\infty} F(s)e^{st} ds, \quad (4-15)$$

where c is a real constant that is greater than the real parts of all the singularities of $F(s)$. Equation (4-15) represents a line integral that is to be evaluated in the s -plane. However, for most engineering purposes the inverse Laplace transform operation can be done simply by referring to the Laplace transform table, such as the one given in Table 4-1. Before using Table 4-1, one may need to do partial-fraction expansion first, then, use the equations in table 4-1.

Partial-fraction expansion when all the poles^() of the transfer function are simple and real:*

Example 4-3: Find the partial-fraction expansion of the following transfer function, and its inverse Laplace.

$$G(s) = \frac{s+3}{(s+1)(s+2)}$$

Solution:

$$G(s) = \frac{s+3}{(s+1)(s+2)} = \frac{A}{s+1} + \frac{B}{s+2}$$

where,

$$A = (s+1)G(s)\Big|_{s=-1} = \frac{s+3}{s+2}\Big|_{s=-1} = \frac{-1+3}{-1+2} = 2$$

and

$$B = (s+2)G(s)\Big|_{s=-2} = \frac{s+3}{s+1}\Big|_{s=-2} = \frac{-2+3}{-2+1} = -1$$

Therefore,

$$G(s) = \frac{s+3}{(s+1)(s+2)} = \frac{2}{s+1} + \frac{-1}{s+2}$$

The inverse Laplace transform of the given transfer function can be obtained by using some equation in Table 4-1, namely,

$$g(t) = \mathcal{L}^{-1}\left(\frac{2}{s+1} + \frac{-1}{s+2}\right) = \mathcal{L}^{-1}\left(\frac{2}{s+1}\right) + \mathcal{L}^{-1}\left(\frac{-1}{s+2}\right) = 2e^{-t} - 1e^{-2t} \quad t \geq 0$$

◆

Note (*): A pole is a value of s that makes a function, such as $G(s)$, infinite, by making the denominator of the function to zero.

Partial-fraction expansion when some poles of the transfer function are of multiple order:

Example 4-4: Find the partial-fraction expansion of the following transfer function, and its inverse Laplace.

$$G(s) = \frac{1}{s^2(s+1)}$$

Solution:

$$G(s) = \frac{1}{s^2(s+1)} = \frac{A_1}{s} + \frac{A_2}{s^2} + \frac{B}{s+1}$$

where,

$$A_2 = [s^2 G(s)]|_{s=0} = \left[\frac{1}{s+1} \right]_{s=0} = 1$$

$$A_1 = \frac{d}{ds} [s^2 G(s)]|_{s=0} = \frac{d}{ds} \left[\frac{1}{s+1} \right]_{s=0} = \left[\frac{-1}{(s+1)^2} \right]_{s=0} = -1$$

and

$$B = (s+1)G(s)|_{s=-1} = \frac{1}{s^2} \Big|_{s=-1} = 1$$

Therefore,

$$G(s) = \frac{1}{s^2(s+1)} = \frac{-1}{s} + \frac{1}{s^2} + \frac{1}{s+1}$$

The inverse Laplace of the given transfer function can be obtained by using equations in Table 4-1, namely,

$$g(t) = \mathcal{L}^{-1} \left(\frac{-1}{s} + \frac{1}{s^2} + \frac{1}{s+1} \right) = \mathcal{L}^{-1} \left(\frac{-1}{s} \right) + \mathcal{L}^{-1} \left(\frac{1}{s^2} \right) + \mathcal{L}^{-1} \left(\frac{1}{s+1} \right) = -1 + t + e^{-t} \quad t \geq 0$$

◆

Example 4-5: Find the partial-fraction expansion of the following transfer function, and its inverse Laplace.

$$G(s) = \frac{1}{s(s+1)^3(s+2)}$$

Solution:

$$G(s) = \frac{1}{s(s+1)^3(s+2)} = \frac{A_1}{s+1} + \frac{A_2}{(s+1)^2} + \frac{A_3}{(s+1)^3} + \frac{B}{s+2} + \frac{C}{s}$$

where

$$A_3 = \left[(s+1)^3 G(s) \right]_{s=-1} = \left[\frac{1}{s(s+2)} \right]_{s=-1} = -1$$

$$A_2 = \frac{d}{ds} \left[(s+1)^3 G(s) \right]_{s=-1} = \frac{d}{ds} \left[\frac{1}{s(s+2)} \right]_{s=-1} = \left[\frac{-(2s+2)}{s^2(s+2)^2} \right]_{s=-1} = 0$$

$$A_1 = \frac{1}{2!} \frac{d^2}{ds^2} \left[(s+1)^3 G(s) \right]_{s=-1} = \frac{1}{2!} \frac{d^2}{ds^2} \left[\frac{1}{s(s+2)} \right]_{s=-1} = \frac{1}{2} \frac{d}{ds} \left[\frac{-2(s+1)}{s^2(s+2)^2} \right]_{s=-1}$$

$$= \left[\frac{-1}{s^2(s+2)^2} + \frac{2(s+1)}{s^2(s+2)^3} + \frac{2(s+1)}{s^3(s+2)^2} \right]_{s=-1} = -1$$

$$B = (s+2)G(s) \Big|_{s=-2} = \frac{1}{s(s+1)^3} \Big|_{s=-2} = \frac{1}{-2(-2+1)} = 0.5$$

and

$$C = sG(s) \Big|_{s=0} = \frac{1}{(s+1)^3(s+2)} \Big|_{s=0} = \frac{1}{(0+1)^3(0+2)} = 0.5$$

Therefore,

$$G(s) = \frac{1}{s(s+1)^3(s+2)} = \frac{-1}{s+1} + \frac{0}{(s+1)^2} + \frac{-1}{(s+1)^3} + \frac{0.5}{s+2} + \frac{0.5}{s}$$

The inverse Laplace of the given transfer function can be obtained by using Table 4-1, namely,

$$g(t) = \mathcal{L}^{-1} \left(\frac{-1}{s+1} + \frac{-1}{(s+1)^3} + \frac{0.5}{s+2} + \frac{0.5}{s} \right) = \mathcal{L}^{-1} \left(\frac{-1}{s+1} \right) + \mathcal{L}^{-1} \left(\frac{-1}{(s+1)^3} \right) + \mathcal{L}^{-1} \left(\frac{0.5}{s+2} \right) + \mathcal{L}^{-1} \left(\frac{0.5}{s} \right)$$

$$= 0.5 - e^{-t} + 0.5e^{-2t} - \frac{1}{(3-1)!} t^{3-1} e^{-t} \quad t \geq 0$$

$$= 0.5 - e^{-t} + 0.5e^{-2t} - 0.5t^2 e^{-t} \quad t \geq 0$$

◆

Partial-fraction expansion with simple complex-conjugate poles:

Example 4-6: Find the partial-fraction expansion of the following transfer function, and its inverse Laplace.

$$G(s) = \frac{\omega_n^2}{s(s^2 + 2\zeta\omega_n s + \omega_n^2)}$$

Solution:

$$G(s) = \frac{\omega_n^2}{s(s^2 + 2\zeta\omega_n s + \omega_n^2)} = \frac{\omega_n^2}{s(s + \alpha - j\omega)(s + \alpha + j\omega)} = \frac{A_1}{s + \alpha - j\omega} + \frac{A_2}{s + \alpha + j\omega} + \frac{B}{s}$$

and

$$\alpha = \zeta\omega_n; \quad \omega = \omega_n \sqrt{1 - \zeta^2}$$

where

$$A_1 = (s + \alpha - j\omega)G(s) \Big|_{s = -\alpha + j\omega} = \frac{\omega_n^2}{s(s + \alpha + j\omega)} \Big|_{s = -\alpha + j\omega} = \frac{\omega_n^2}{(-\alpha + j\omega)(2j\omega)} = \frac{\omega_n}{2\omega} e^{-j\left(\theta + \frac{\pi}{2}\right)}$$

$$A_2 = (s + \alpha + j\omega)G(s) \Big|_{s = -\alpha - j\omega} = \frac{\omega_n^2}{s(s + \alpha - j\omega)} \Big|_{s = -\alpha - j\omega} = \frac{\omega_n^2}{(-\alpha - j\omega)(-2j\omega)} = \frac{\omega_n}{2\omega} e^{j\left(\theta + \frac{\pi}{2}\right)}$$

with $\theta = \tan^{-1} \left[\frac{\omega}{-\alpha} \right]$ (please note this angle is in the second quadrant)

and

$$B = sG(s) \Big|_{s=0} = \frac{\omega_n^2}{(s^2 + 2\zeta\omega_n s + \omega_n^2)} \Big|_{s=0} = 1$$

Therefore,

$$G(s) = \frac{\omega_n^2}{s(s^2 + 2\zeta\omega_n s + \omega_n^2)} = \frac{\omega_n}{2\omega} \left[\frac{e^{-j\left(\theta + \frac{\pi}{2}\right)}}{s + \alpha - j\omega} + \frac{e^{j\left(\theta + \frac{\pi}{2}\right)}}{s + \alpha + j\omega} \right] + \frac{1}{s}$$

The inverse Laplace of the given transfer function can be obtained by using Table 4-1, namely,

$$\begin{aligned} g(t) &= 1 + \frac{\omega_n}{2\omega} \left[e^{-j\left(\theta + \frac{\pi}{2}\right)} e^{(-\alpha + j\omega)t} + e^{j\left(\theta + \frac{\pi}{2}\right)} e^{(-\alpha - j\omega)t} \right] = 1 + \frac{\omega_n}{2\omega} e^{-\alpha t} \left[e^{-j\left(\theta + \frac{\pi}{2} - \omega t\right)} + e^{j\left(\theta + \frac{\pi}{2} - \omega t\right)} \right] \\ &= 1 + \frac{\omega_n}{\omega} e^{-\alpha t} \left[\frac{e^{j\left(\omega t - \theta - \frac{\pi}{2}\right)} + e^{-j\left(\omega t - \theta - \frac{\pi}{2}\right)}}{2} \right] = 1 + \frac{\omega_n}{\omega} e^{-\alpha t} \left[\frac{e^{j(\omega t - \theta)} - e^{-j(\omega t - \theta)}}{2j} \right] = 1 + \frac{\omega_n}{\omega} e^{-\alpha t} \sin(\omega t - \theta) \end{aligned}$$

$$= 1 + \frac{1}{\sqrt{1 - \zeta^2}} e^{-\zeta\omega_n t} \sin(\omega_n \sqrt{1 - \zeta^2} t - \theta) \quad t \geq 0$$

where

$$\theta = \tan^{-1} \left[\frac{\sqrt{1 - \zeta^2}}{-\zeta} \right]$$

◆

Laplace Transform Table:

Table 4-1: Laplace Transform Table.

Laplace Transform, F(s)	Time Function, f(t)
1	$\delta(t)$ (Impulse at $t = 0$)
$\frac{1}{s}$	$u_s(t)$ (Unit Step at $t = 0$)
$\frac{1}{s^2}$	t (or $t [u(t)]$, Ramp at $t = 0$)
$\frac{n!}{s^{n+1}}$	t^n ($n =$ positive integer)
$\frac{1}{s + a}$	e^{-at}
$\frac{1}{(s + a)(s + b)}$	$\frac{e^{-at} - e^{-bt}}{b - a}$
$\frac{\omega_n}{s^2 + \omega_n^2}$	$\sin \omega_n t$
$\frac{s}{s^2 + \omega_n^2}$	$\cos \omega_n t$
$\frac{1}{(s + a)^2}$	te^{-at}
$\frac{n!}{(s + a)^{n+1}}$	$t^n e^{-at}$
$\frac{\omega_n}{(s + a)^2 + \omega_n^2}$	$e^{-at} \sin \omega_n t$
$\frac{s + a}{(s + a)^2 + \omega_n^2}$	$e^{-at} \cos \omega_n t$

$\frac{1}{(1+sT)^n}$	$\frac{1}{T^n(n-1)!}t^{n-1}e^{-\frac{t}{T}}$
$\frac{\omega_n^2}{s^2 + 2\zeta\omega_n s + \omega_n^2}$	$\frac{\omega_n}{\sqrt{1-\zeta^2}}e^{-\zeta\omega_n t}\sin\omega_n\sqrt{1-\zeta^2}t$
$\frac{\omega_n^2}{s(s^2 + 2\zeta\omega_n s + \omega_n^2)}$	$1 + \frac{1}{\sqrt{1-\zeta^2}}e^{-\zeta\omega_n t}\sin(\omega_n\sqrt{1-\zeta^2}t - \phi)$ where $\phi = \tan^{-1}\frac{\sqrt{1-\zeta^2}}{-\zeta}$
$\frac{s\omega_n^2}{s^2 + 2\zeta\omega_n s + \omega_n^2}$	$\frac{\omega_n^2}{\sqrt{1-\zeta^2}}e^{-\zeta\omega_n t}\sin(\omega_n\sqrt{1-\zeta^2}t + \phi)$ where $\phi = \tan^{-1}\frac{\sqrt{1-\zeta^2}}{-\zeta}$
$\frac{1}{s(1+sT)}$	$1 - e^{-\frac{t}{T}}$
$\frac{1}{s(1+sT)^2}$	$1 - \frac{t+T}{T}e^{-\frac{t}{T}}$
$\frac{1}{s^2(1+sT)^2}$	$t - 2T + (t+2T)e^{-\frac{t}{T}}$
$\frac{1+as}{s^2(1+sT)}$	$t + (a-T)\left(1 - e^{-\frac{t}{T}}\right)$
$\frac{s}{(s^2 + \omega_n^2)^2}$	$\frac{1}{2\omega_n}t\sin\omega_n t$
$\frac{s}{(s^2 + \omega_{n1}^2)(s^2 + \omega_{n2}^2)}$	$\frac{1}{\omega_{n2}^2 - \omega_{n1}^2}(\cos\omega_{n1}t - \cos\omega_{n2}t)$
$\frac{s^2}{(s^2 + \omega_n^2)^2}$	$\frac{1}{2\omega_n}(\sin\omega_n t + \omega_n t \cos\omega_n t)$

V. Time-Domain Analysis:

The time response of a control system is usually divided into two parts: the transient response and the steady-state response. Let $c(t)$ denote a time response and be expressed as follows:

$$c(t) = c_t(t) + c_{ss}(t), \quad (5-1)$$

where $c_t(t)$ is the transient response and $c_{ss}(t)$ is the steady-state response.

Typical Test Signals:

To facilitate the time-domain analysis, the following input test signals are often used.

Step Function: The step function represents an instantaneous change in the reference input variable. At time $t < 0$, the signal is zero while at $t \geq 0$, the signal is R , namely,

$$r(t) = \begin{cases} R & t \geq 0 \\ 0 & t < 0 \end{cases}, \quad (5-2)$$

where R is a constant. Or,

$$r(t) = Ru_s(t), \quad (5-3)$$

where $u_s(t)$ is the unit step function. The step function as a function of time is shown in Figure 5-1.




Fig. 5-1. Step function input.

Ramp Function: The ramp function is a signal to have a constant change in value at the same rate with respect to time and can be expressed as

$$r(t) = \begin{cases} Rt & t \geq 0 \\ 0 & t < 0 \end{cases}. \quad (5-4)$$

As one can see, the slope of the signal is a constant, R . The ramp function is shown in Figure 5-2.




Fig. 5-2. Ramp function input.

Parabolic Function: The mathematical representation of a parabolic function is expressed as follows:

$$r(t) = \begin{cases} \frac{R}{2} t^2 & t \geq 0 \\ 0 & t < 0 \end{cases} \quad (5-5)$$

The graphical representation of the parabolic function is shown in Figure 5-3.




Fig. 5-3. Parabolic function input.

Steady-State Error of Linear Systems:

A closed-loop system with a negative feedback is shown in Figure 5-4. The output can be expressed as a function of the input as follows:




Fig. 5-4. A closed-loop system with a negative feedback.

$$C(s) = \frac{G(s)}{1 + G(s)H(s)} R(s). \quad (5-6)$$

Also, the error, $E(s)$, can be expressed as:

$$E(s) = R(s) - H(s)C(s), \quad (5-7)$$

then,

$$E(s) = \left[1 - \frac{G(s)H(s)}{1 + G(s)H(s)} \right] R(s) = \frac{1}{1 + G(s)H(s)} \cdot R(s). \quad (5-8)$$

The steady-state error in time domain can be obtained by applying the final-value theorem, namely,

$$e_{ss}(t) = \lim_{t \rightarrow \infty} e(t) = \lim_{s \rightarrow 0} sE(s) = \lim_{s \rightarrow 0} s \cdot \frac{1}{1 + G(s)H(s)} \cdot R(s). \quad (5-9)$$

Typically, the inputs for steady-state error considerations are:

(1) If the input is a step function, $u(t)$, of magnitude R , or R/s in Laplace transform. Then, the steady-state error of the system can be denoted as

$$e_{ss}(t) = \lim_{s \rightarrow 0} s \cdot \frac{1}{1 + G(s)H(s)} \cdot R(s) = \lim_{s \rightarrow 0} s \cdot \frac{1}{1 + G(s)H(s)} \cdot \frac{R}{s} = \lim_{s \rightarrow 0} \frac{R}{1 + G(s)H(s)}. \quad (5-10)$$

If one defines

$$K_p = \lim_{s \rightarrow 0} G(s)H(s), \quad (5-11)$$

where K_p is the step error constant (or position error constant). Then, the equation (5-10) can be simplified as

$$e_{ss}(t) = \lim_{s \rightarrow 0} \frac{R}{1 + G(s)H(s)} = \frac{R}{1 + \lim_{s \rightarrow 0} G(s)H(s)} = \frac{R}{1 + K_p}. \quad (5-12)$$

One can easily realize that to have the steady-state error to be zero when the input is a step function, K_p must be infinite. The steady-state error due to a unit step function input is also called the steady-state position error.

(2) If the input is a ramp function, its Laplace transform can be expressed as

$$R(s) = \frac{R}{s^2}. \quad (5-13)$$

Then, the steady-state error of the system is

$$e_{ss}(t) = \lim_{s \rightarrow 0} s \cdot \frac{1}{1 + G(s)H(s)} \cdot \frac{R}{s^2} = \lim_{s \rightarrow 0} \frac{1}{s + sG(s)H(s)} = \frac{R}{\lim_{s \rightarrow 0} s G(s)H(s)}. \quad (5-14)$$

If one defines

$$K_v = \lim_{s \rightarrow 0} s G(s)H(s), \quad (5-15)$$

where K_v is the ramp error constant (or velocity error constant). Therefore, the equation (5-14) can be simplified as

$$e_{ss}(t) = \frac{R}{K_v}. \quad (5-16)$$

Therefore, to have zero steady-state error, K_v needs to be infinite. The steady-state error due to a unit ramp function input is called the steady-state velocity error.

(3) If the input is a parabolic input, its transfer function is listed below

$$R(s) = \frac{R}{s^3}. \quad (5-17)$$

The steady-state error of the system can be obtained as follows

$$e_{ss}(t) = \lim_{s \rightarrow 0} s \cdot \frac{1}{1 + G(s)H(s)} \cdot \frac{R}{s^3} = \lim_{s \rightarrow 0} \frac{1}{s^2 + s^2 G(s)H(s)} = \frac{R}{\lim_{s \rightarrow 0} s^2 G(s)H(s)}. \quad (5-18)$$

If one defines the parabolic error constant (or acceleration error constant),


$$K_a = \lim_{s \rightarrow 0} s^2 G(s)H(s). \quad (5-19)$$

Then, the steady-state error due to a parabolic input can be written as

$$e_{ss}(t) = \frac{R}{K_a}, \quad (5-20)$$

and it is also called the steady-state acceleration error.

Example 5-1: A closed-loop system is shown below.



- (A) For $K = 10$, what is the steady-state error to a unit step input?
 (B) For $K = 10$, what is the steady-state error to a unit ramp input?
 (C) For $K = 10$, what is the steady-state error to a unit parabolic input?
 (D) Find the value of K such that the steady-state error to a unit ramp input is 5%.

Solution:

(A) For a unit step input and $K = 10$:

$$K_p = \lim_{s \rightarrow 0} G(s)H(s) = \lim_{s \rightarrow 0} \left[\frac{10(s+6)}{s(s+2)(s+4)} \right] \cdot 1 = \infty.$$

$$e_{ss}(t) = \frac{1}{1+K_p} = \frac{1}{1+\infty} = 0.$$

(B) For a unit ramp input and $K = 10$:

$$K_v = \lim_{s \rightarrow 0} s G(s)H(s) = \lim_{s \rightarrow 0} s \left[\frac{10(s+6)}{s(s+2)(s+4)} \right] \cdot 1 = \lim_{s \rightarrow 0} \frac{10(s+6)}{(s+2)(s+4)} = \frac{60}{8} = 7.5$$

$$e_{ss}(t) = \frac{1}{K_v} = \frac{1}{7.5} = 0.1333 = 13.33\%.$$

(C) For a Parabolic input and $K = 10$:

$$K_a = \lim_{s \rightarrow 0} s^2 G(s)H(s) = \lim_{s \rightarrow 0} s^2 \left[\frac{10(s+6)}{s(s+2)(s+4)} \right] \cdot 1 = \lim_{s \rightarrow 0} s \cdot \frac{10(s+6)}{(s+2)(s+4)} = 0.$$

$$e_{ss}(t) = \frac{1}{K_a} = \frac{1}{0} = \infty.$$

(D) From part (B), for a unit ramp input,

$$K_v = \lim_{s \rightarrow 0} s G(s)H(s) = \lim_{s \rightarrow 0} s \left[\frac{K(s+6)}{s(s+2)(s+4)} \right] \cdot 1 = \lim_{s \rightarrow 0} \frac{K(s+6)}{(s+2)(s+4)} = \frac{6K}{8}$$

$$e_{ss}(t) = \frac{1}{K_v} = \frac{1}{\frac{6K}{8}} = 5\% = 0.05.$$

$$K = \frac{8}{6 \cdot (0.05)} = \frac{80}{3}.$$

◆

Type of Feedback Control System:

A stable system can be classified according to the degree of the polynomial for which the error is a constant, and the classification is called the system type. In general, the open-loop transfer function $G(s)H(s)$ can be written as

$$G(s)H(s) = \frac{K(1+a_1s)(1+a_2s)\cdots(1+a_ms)}{s^T(1+b_1s)(1+b_2s)\cdots(1+b_ns)}, \quad (5-21)$$

where that K , all a 's and b 's are constants and the $T = 0, 1, 2, \dots$. The type of feedback control system is referring to the order of the pole of $G(s)H(s)$ at $s = 0$. Therefore, the system is of type T . For instance, a feedback control system with

$$G(s)H(s) = \frac{5(1 + 2s)}{s(1 + 3s)(1 + 4s)}$$

is of type 1.

The significance of system types is as follows (when restricted to unity feedback systems):


- Type 0: System has a non-zero steady-state error to a step input.
- Type 1: System has zero steady-state error to a step input. It has a non-zero steady-state error to a ramp input.
- Type 2: System has zero steady-state error to both a step input and a ramp input. It has a non-zero steady-state error to a parabolic input.

The following summary of the Steady-State Errors due to Step, Ramp and Parabolic inputs can be constructed, as shown in Table 5-1, where T denotes the type of system.

Table 5-1: Steady-State Error analysis table.

Type	K_p	K_v	K_a	Step	Ramp	Parabolic (Acceleration)
$T = 0$	K	0	0	$e_{ss} = \frac{R}{1 + K_p}$	$e_{ss} = \infty$	$e_{ss} = \infty$
$T = 1$	∞	K	0	$e_{ss} = 0$	$e_{ss} = \frac{R}{K_v}$	$e_{ss} = \infty$
$T = 2$	∞	∞	K	$e_{ss} = 0$	$e_{ss} = 0$	$e_{ss} = \frac{R}{K_a}$
$T \geq 3$	∞	∞	∞	$e_{ss} = 0$	$e_{ss} = 0$	$e_{ss} = 0$


Example 5-2. For the given system with its block diagram listed below:



- (A) Find the overall closed-loop transfer function.
- (B) If $T = 0$, find the steady-state position error and velocity error.
- (C) If $T = 1$, find the steady-state position error and velocity error.

Solution:

- (A) One can obtain the overall transfer function by applying rules of simplifying block diagram.



One may first apply case 3 in Table 1-1 to obtain the transfer function for the inner closed-loop as

$$G(s) = \frac{\frac{5}{s^T(1+s)}}{1 + \frac{5}{s^T(1+s)} \cdot s} = \frac{5}{s^T(1+s) + 5s}$$

Then, use case 3 once again with a unity feedback ($H(s)=1$), therefore, the overall transfer function can be obtained as

$$\frac{C(s)}{R(s)} = \frac{\frac{5}{s^T(1+s) + 5s}}{1 + \frac{5}{s^T(1+s) + 5s} \cdot 1} = \frac{5}{s^T(1+s) + 5s + 5}$$

Or, one can use Mason Rule and get the overall transfer function as

$$\frac{C(s)}{R(s)} = \frac{\frac{5}{s^T(1+s)}}{1 + \frac{5}{s^T(1+s)} \cdot s + \frac{5}{s^T(1+s)} \cdot 1} = \frac{5}{s^T(1+s) + 5s + 5}$$

- (B) $T = 0$, the open-loop transfer function $G(s)H(s)$ is

$$G(s)H(s) = \frac{5}{(1+s) + 5s} = \frac{5}{1+6s}$$

To find the steady-state position error, the input is assumed as a unit step input,

$$R(s) = \frac{1}{s}, \text{ and the position error constant can be calculated as}$$

$$K_p = \lim_{s \rightarrow 0} G(s)H(s) = \lim_{s \rightarrow 0} \left[\frac{5}{1+6s} \right] \cdot 1 = 5.$$

Therefore, the steady-state position error can be obtained, namely,

$$e_{ss,p}(t) = \frac{1}{1+K_p} = \frac{1}{1+5} = \frac{1}{6}.$$

To find the steady-state velocity error, the input is assumed as a unit ramp input,

$$R(s) = \frac{1}{s^2}, \text{ and the velocity error constant can be calculated as}$$

$$K_v = \lim_{s \rightarrow 0} s G(s)H(s) = \lim_{s \rightarrow 0} s \cdot \frac{5}{1+6s} = 0.$$

Therefore, the steady-state velocity error is

$$e_{ss,v}(t) = \frac{1}{K_v} = \frac{1}{0} = \infty.$$

(C) $T = 1$, the open-loop transfer function $G(s)H(s)$ is

$$G(s)H(s) = \frac{5}{s(1+s)+5s} = \frac{5}{s(s+6)}.$$

To find the steady-state position error, the input is assumed as a unit step input,

$$R(s) = \frac{1}{s}, \text{ and the position error constant can be calculated as}$$

$$K_p = \lim_{s \rightarrow 0} G(s)H(s) = \lim_{s \rightarrow 0} \left[\frac{5}{s(s+6)} \right] \cdot 1 = \infty.$$

Therefore, the steady-state position error can be obtained, namely,

$$e_{ss,p}(t) = \frac{1}{1+K_p} = \frac{1}{1+\infty} = 0.$$

To find the steady-state velocity error, the input is assumed as a unit ramp input,

$$R(s) = \frac{1}{s^2}, \text{ and the velocity error constant can be calculated as}$$

$$K_v = \lim_{s \rightarrow 0} s G(s)H(s) = \lim_{s \rightarrow 0} s \cdot \frac{5}{s(s+6)} = \lim_{s \rightarrow 0} \frac{5}{s+6} = \frac{5}{6}.$$

Therefore, the steady-state velocity error is

$$e_{ss,v}(t) = \frac{1}{K_v} = \frac{1}{5/6} = \frac{6}{5}.$$

◆

First-Order Systems:

The transfer function of a first-order system can be expressed as

$$G(s) = \frac{C(s)}{R(s)} = \frac{1}{s\tau + 1}, \quad (5-22)$$

and, the output of the system can be written as

$$C(s) = \frac{1}{s\tau + 1} \cdot R(s). \quad (5-23)$$

The unit step response of the system in time domain can be obtained by inverse of the Laplace transform, or using the formula listed in Table 4-1, namely,

$$c(t) = \mathcal{L}^{-1}[C(s)] = \mathcal{L}^{-1}\left[\frac{1}{s\tau + 1} \cdot \frac{1}{s}\right] = \mathcal{L}^{-1}\left[\frac{1}{s} + \frac{-1}{s + \frac{1}{\tau}}\right] = 1 - e^{-\frac{t}{\tau}} \quad t \geq 0, \quad (5-24)$$

where τ is the time constant of the given control system. By plotting the output signal in time domain, Figure 5-5 can be obtained.




Fig. 5-5. Typical unit step input response of a first-order system.

Classical Second-Order Systems:

Although true second-order control systems are rare in practice, their analysis generally helps to form a basis for understanding of design and analysis techniques. The transfer function of a classical second-order system can be represented as

$$\frac{C(s)}{R(s)} = \frac{\omega_n^2}{s^2 + 2\zeta\omega_n s + \omega_n^2}, \quad (5-25)$$

where

$$\zeta = \text{damping ratio} \quad \begin{array}{l} \zeta > 1 : \text{overdamped,} \\ \zeta = 1 : \text{critically damped,} \\ \zeta < 1 : \text{underdamped,} \end{array}$$

and

$$\omega_n = \text{undamped natural frequency.}$$

When $\zeta < 1$ and a unit step is injected into the system,

$$c(t) = 1 - \frac{1}{\sqrt{1-\zeta^2}} e^{-\zeta\omega_n t} \sin(\sqrt{1-\zeta^2}\omega_n t + \phi), \quad (5-26)$$

where

$$\phi = \tan^{-1}\left(\frac{\sqrt{1-\zeta^2}}{\zeta}\right). \quad (5-27)$$

The time domain plot for such a second-order system with a unit step input is shown in Figure 5-6.




Fig. 5-6. The typical unit step input response of a second-order system.

There are some important performance criteria that are typically used to characterize the transient response to a unit step input include percent (maximum) overshoot, peak time, rise time and settling time.

Percent overshoot: the percentage of the maximum overshoot (the largest deviation of the output over the step input during the transient state).

$$\%OS = e^{-\frac{\zeta\pi}{\sqrt{1-\zeta^2}}} \times 100\% . \quad (5-28)$$

Peak time: The time it takes to reach the first peak.

$$t_p = \frac{\pi}{\omega_n \sqrt{1-\zeta^2}} \text{ seconds.} \quad (5-29)$$


Rise time: The time required for the output to rise from 10% of the final value to 90% of the final values.

$$t_r = \frac{0.8 + 2.5\zeta}{\omega_n} \text{ seconds.} \quad (5-30)$$

Settling time: The time it takes for the system to settle within certain percentage of the final value.

$$t_s = \frac{4}{\zeta\omega_n} \text{ seconds. (for 2\%)} \quad (5-31)$$

Example 5-3: The transfer function of the second order system given below is obtained in



Example 1-1 as $\frac{C(s)}{R(s)} = \frac{4}{s^2 + s + 4}$. What are the percent overshoot, peak time, rise time and the settling time for this system?


Solution:

By comparing the actual transfer function of the system with the classical second-order equation, namely,


$$\frac{C(s)}{R(s)} = \frac{4}{s^2 + s + 4} = \frac{\omega_n^2}{s^2 + 2\zeta\omega_n s + \omega_n^2}$$

One should be able to obtain the undamped natural frequency and the damping ratio as

$$\omega_n = 2; \zeta = \frac{1}{2\omega_n} = 0.25$$



$$\frac{C(s)}{R(s)} = \frac{4}{s^2 + s + 4} = \frac{\omega_n^2}{s^2 + 2\zeta\omega_n s + \omega_n^2}$$



% Overshoot: $\%OS = e^{-\frac{\zeta\pi}{\sqrt{1-\zeta^2}}} \times 100 = e^{-\frac{0.25\pi}{\sqrt{1-0.25^2}}} \times 100 = 44.43\%$

Peak time: $t_p = \frac{\pi}{\omega_n\sqrt{1-\zeta^2}} = \frac{\pi}{2\sqrt{1-0.25^2}} = 1.6223 \text{ seconds}$


Rise time: $t_r = \frac{0.8 + 2.5\zeta}{\omega_n} = \frac{0.8 + 2.5 \times 0.25}{2} = 0.7125 \text{ second}$

Settling time: $t_s = \frac{4}{\zeta\omega_n} = \frac{4}{0.25 \times 2} = 8 \text{ seconds (for 2\%)}$

If one uses Matlab/Simulink to model this simple system, one should be able to get the plot shown above and confirm the answers obtained with equations (5-28)~(5-31).



Example 5-4: Find K and a for the closed-loop system below such that the transient response to a step input satisfies: $\%OS \leq 5\%$ & $t_s \leq 4$ seconds



Solution:

The transfer function of the system can be obtained as

$$\frac{C(s)}{R(s)} = \frac{\frac{K}{s(s+a)}}{1 + \frac{K}{s(s+a)}} = \frac{K}{s^2 + as + K} = \frac{\omega_n^2}{s^2 + 2\zeta\omega_n s + \omega_n^2}$$

Therefore,

$$K = \omega_n^2; \quad a = 2\zeta\omega_n$$

The percent overshoot is required to be less than or equal to 5%, hence,

$$\%OS = e^{-\frac{\zeta\pi}{\sqrt{1-\zeta^2}}} \times 100\% = 5\%$$

$$\Rightarrow -\frac{\zeta\pi}{\sqrt{1-\zeta^2}} = \ln(0.05) = -2.995732$$

$$\Rightarrow (0.95357)\sqrt{1-\zeta^2} = \zeta$$

$$\Rightarrow 0.9093 - 0.9093\zeta^2 = \zeta^2$$

$$\Rightarrow \zeta^2 = \frac{0.9093}{1.9093}$$

$$\Rightarrow \zeta = \sqrt{\frac{0.9093}{1.9093}} = \sqrt{0.47625} = 0.69$$

To find the undamped natural frequency, one needs to use the other given condition, namely,

$$t_s = \frac{4}{\zeta\omega_n} = 4$$

$$\Rightarrow \zeta\omega_n = 1$$

$$\Rightarrow \omega_n = \frac{1}{\zeta} = \frac{1}{0.69} = 1.4491$$


Now, one should be able to find K and a as follows:

$$K = \omega_n^2 = 2.1$$

and

$$a = 2\zeta\omega_n = 2 \cdot 1 = 2$$

Other than using Matlab/Simulink to verify the solution, one may use a spreadsheet to plot the output as given by equations (5-26) and (5-27).



References:

- [1] Gene F. Franklin, J. David Powell and Abbas Emami-Naeini, *Feedback Control of Dynamic Systems – 2nd Edition*, Addison Wesley, 1991
- [2] Benjamin C. Kuo, *Automatic Control Systems – 5th Edition*, Prentice-Hall, 1987
- [3] John A. Camara, *Practice Problems for the Electrical and Computer Engineering PE Exam – 6th Edition*, Professional Publications, 2002
- [4] NCEES, *Fundamentals of Engineering Supplied-Reference Handbook – 6th Edition*, 2003
- [5] Merle C. Potter, *FE/EIT Electrical Discipline-Specific Review for the FE/EIT Exam – 5th Edition*, Great Lakes Press, 2001
- [6] Merle C. Potter, *Principles & Practice of Electrical Engineering – 1st Edition*, Great Lakes Press, 1998